Approved For Release 2009/03/20 : CIA-RDP89-00244R000801860006-8

(K Utilities)

P-KM Larry

Conditions of Circuits as of 7/13/84

Cir # 1 · Clear + operating

Cir # 2 · Has mupitial shorts to ground + operating to short. Locations of shorts Unknown.

Cir # 3. Has shorts Between poles 180 + 178
Megs 25 Megohms At 2.5 KV. Pole 180 to Transformer
Megs 1.12 " " 1 KV Pole 178 to Transformer.
Cable Breaks down Between 1.5 + 2 KV

Cir # 4 - Has short Between Pole # 172 + 176
all lts operating except #176 which has open Ballest.
Wire megd At pole 176 300 Meg ohms At 2.5 KV
" " At pole # 172. 14 Meg ohms At 2.5 KV
to transformer from Both poles.

J. Briggs
1-2 Eagles

Approved For Release 2009/03/20 : CIA-RDP89-00244R000801860006-8